



Ref. Certif. No.

DK-13254-A3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

Name and address of the applicant
Nom et adresse du demandeur

Name and address of the manufacturer
Nom et adresse du fabricant

Name and address of the factory
Nom et adresse de l'usine

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{me} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)

Model / Type Ref.
Ref. De type

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent
être indiqués sur la 2^{me} page)

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

As shown in the Test Report Ref. No. which forms part of
this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

Power Supply

**VOX POWER LTD
TERENURE ENTERPRISE CENTRE
17 RATHFARNHAM ROAD, TERENURE
DUBLIN 6W IRELAND
VOX POWER LTD
TERENURE ENTERPRISE CENTRE
17 RATHFARNHAM ROAD, TERENURE
DUBLIN 6W IRELAND
CELETRONIX POWER (INDIA) PVT LTD
UNIT 41 SDF-II
SEEPZ ANDHERI (E)
MUMBAI MH 400096 INDIA**

See appendix, IP X0, Class I



NEVO600x-abcd-zzzz or NEVO+600x-abcd-zzzz, See appendix

This certificate is an amendment to CB-certificate DK-13254-A2 dated 2009-11-17 due to add a new model and update of the critical component table. Also investigated to EN 60950-1:2001 + A11:2004.

PUBLICATION	EDITION
IEC 60950-1:2001	1st

E316486-A1-CB-1 Amendment 3 dated 2009-12-17



Date:
2009-12-17

UL International Demko A/S
Lyskaer 8, P.O. Box 514, DK-2730 Herlev, Denmark
Tel: +45 44856565, Fax: +45 44856500

Signature:

Jan-Erik Storgaard
Certification manager



Ref. Certif. No.

DK-13254-A3

Model/Type reference:

NEVO600x-abcd-zzzz or NEVO+600x-abcd-zzzz

where x=S or M, and where:

a (slot A)=0,1,2, 3, 4 or 5;

b (slot B)=0,1,2, 3, 4 or 5;

c (slot C)=0,1,2, 3, 4 or 5;

d (slot D)=0,1,2, 3, 4 or 5; and

where 0=No Module (blanking plate fitted); 1=OP1, 2=OP2; 3=OP3, 4=OP4, 5=OP5.

May also be followed by up to 4 alphanumeric zzzz indicating non-safety related information.

Output Modules:

OP1;

OP2;

OP3;

OP4;

OP5.

Rating(s): NEVO600x-abcd-zzzz: 100-240Vac, 4.5A, 50-60Hz and 120-370Vdc, 4.5A

NEVO+600x-abcd-zzzz: 100-240Vac, 6A, 50-60Hz and 120-370Vdc, 6A

Maximum output power 600W. Individual outputs rated according to modules fitted.

Output Module Output Ratings:

OP1=1.5-7.5Vdc, 25A, 125W.

OP2=4.5-15Vdc, 15A, 150W.

OP3=9-30Vdc, 7.5A, 150W.

OP4=18-58Vdc, 3.75A, 150W.

OP5=5-15Vdc, 5A, 150W and/or 5-15Vdc, 5A, 150W.

(OP5 may have either 1 or 2 outputs)

All output module current and power ratings are the maximum allowable.

for building-in

Additional information (if necessary)

Information complémentaire (si nécessaire)



Underwriters
Laboratories

Date: 2009-12-17

UL International Demko A/S

Lyskaer 8, P.O. Box 514, DK-2730 Herlev, Denmark

Tel: +45 44856565, Fax: +45 44856500

Signature:

Jan-Erik Storgaard
Certification manager